



425 10<sup>th</sup> Street, Douglas, Arizona 85607, (520) 417-7317

## Addendum #1

### RFP # 2020-PW-006 DOC LIFT STATION BAR SCREEN/ WASHER COMPACTOR

This addendum adds alternative manufactures as referenced in Part 2-Products, of the Special Provisions section of the RFP. Adding language as follows: **Huber Multi-Rake Screen RakeMax and Huber Wap Screening Wash and Press will be considered as an alternative manufacturer of the bar screen and washer compactor.**

The equipment submitted is acceptable to the Public Works Department with these notations:

- The information submitted is lacking some of the detail requested in the Special Provisions included in the bid package
- It will be the Contractor's responsibility to provide a fully functional equipment installation. Any additional work, materials or modifications required to install the alternative equipment shall be provided by the Contractor at no extra charge to the City of Douglas. Of specific note-
  - Freeze protection is required for the washer/compactor. The information provided does not address this.
  - The waste material from the washer/compactor is to be bagged using the bagging system specified in the Special Provisions, not deposited in a dumpster
  - The electrical service is adequate for 2, 1 Hp motors operating simultaneously. The information provided does not show the electrical requirements of the proposed equipment.
- The alternative equipment is to be mounted to the existing influent channel. Any additional concrete slabs, footings or mounting equipment shall be provided by the contractor at no additional charge to the City.
- The bar screen must fit within the existing influent channel. Major structural modifications of the channel are prohibited.
- The proposed equipment has an alternative chain made of galvanized steel. Any components specified to be made of stainless steel in the special provisions shall constructed of stainless steel on the alternative equipment supplied.
- The alternative equipment shall be suitable for mounting outdoors, in an unprotected location.
- The controls provided shall meet the requirements of the Special Provisions.

This addendum also adds a second alternative manufacturer:

**JWC MC Multi-Rake Screen and MWP0019 Compactor will be considered as an alternative manufacturer of the bar screen and compactor.**

It will be the Contractor's responsibility to provide a fully functional equipment installation. Any additional work, materials or modifications required to install the alternative equipment shall be provided by the Contractor at no extra charge to the City of Douglas.

Of specific note-

- Freeze protection is required for the washer/compactor. The information provided shows that this is optional equipment. The cost for freeze protection is to be included in the base bid.
- The waste material from the washer/compactor is to be bagged using the bagging system specified in the Special Provisions. The submittal shows the bagging

system to be optional equipment. The bagging system cost shall be included in the base bid. The bagging system MUST use the bags specified in the project Special Provisions.

- The electrical service is adequate for 2, 1 Hp motors operating simultaneously. The information provided does not show the electrical requirements of the proposed equipment.
- The alternative equipment is to be mounted to the existing influent channel. Any additional concrete slabs, footings or mounting equipment shall be provided by the contractor at no additional charge to the City.
- The bar screen must fit within the existing influent channel. Major structural modifications of the channel are prohibited.
- The alternative equipment shall be suitable for mounting outdoors, in an unprotected location.
- The controls provided shall meet the requirements of the Special Provisions.

This addendum extends the bid acceptance period from 8/13/2020 to 8/27/2020 and adds the acceptance of electronic proposal acceptance

The City of Douglas will receive sealed Bid Proposals **and/or emailed Bid Proposals** until Four O'clock p.m. (4:00 p.m.) on the **27th day of August, 2020**. **Emailed Bid proposals shall be emailed to [rene.rios@douglasaz.gov](mailto:rene.rios@douglasaz.gov).**