



PWS ID AZ04-02014

Alan Humphrey, P.E.  
Public Works Director/City Engineer  
Office: 520.417.7329

# Drinking Water Quality Report for 2020

City of Douglas Department of Public Works

June 2021

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúscalo ó hable con alguien que lo entienda bien. También puede obtenerse una copia en español llamando a (520) 417-7329. If you are a non-English speaking resident, we recommend that you speak with someone who understands the report.

We are pleased to present the Annual Drinking Water Quality Report for calendar year 2020. The Federal Safe Drinking Water Act requires that we issue an annual Consumer Confidence Report.

## Drinking Water Source

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

## Douglas Water Source

The City of Douglas serves approximately 16,656 people. There are presently six (6) deep wells that produce high-quality water for public distribution in the City. Hydrologic studies have indicated that the water resources available are generous, with active recharge from the Mule, Dragoon, and Chiricahua mountain ranges. Water stored in the sand and gravel beds of the Douglas Basin Aquifer is adequate to supply our needs for years to come. The wells are widely separated to minimize the risk of any potential local contamination or naturally occurring quality problems. Each of the wells is individually tested to ensure compliance with all applicable standards and regulations. Not all wells are necessary to provide daily needs, but all are run periodically to keep them in operating condition. The average daily usage in our community in the winter time is 2.7 million gallons per day. Peak usage in our community in the summertime is approximately 4.8 million gallons per day. Each well is equipped with its own gas chlorinator to provide sufficient amount of chlorine for protection from bacteria. The City of Douglas continues to work diligently to achieve compliance with all safe drinking water standards and regulations. On March 6, 2019 the Arizona Department of Environmental Quality (ADEQ) conducted an inspection of our Water Distribution System and the report confirmed that we are in full compliance. We continue in our commitment to provide high quality and safe drinking water to all City customers.

## Drinking Water Contaminates

**Microbial contaminants**, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

**Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

**Pesticides, herbicides** that may come from a variety of sources, i.e. agriculture, urban stormwater runoff, and residential uses.

**Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and also may come from gas stations, urban stormwater runoff, and septic systems.

**Radioactive contaminants**, that can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the Arizona Department of Environmental Quality prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

## Vulnerable Population

Drinking water, including bottled water, may be reasonably expected to contain at least small amounts of contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS, or other immune system disorders, some elderly, and infants can be particularly at risk of infections. These people should seek advice about drinking water from their health care providers. For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and microbiological contaminants, call the EPA Safe Drinking Water Hotline at 1-800-426-4791.

## Source Water Assessment

The ADEQ conducted a source water assessment for our City water wells. The assessment included the review of

**Definitions / Acronyms (for the City's Water System Contaminants Table)**

**AL-Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements. **MCL** - Maximum Contaminant Level - the maximum level of a contaminant allowed in drinking water. **MCLG** - Maximum Contaminant Level Goal - the level of a contaminant in drinking water below which there are no known or expected health risks. **MFL** - Million Fibers per Liter. **MRDLG** - Maximum Residual Disinfectant Level Goal. **MREM** - Millirems per year - a measure of radiation absorbed by the body. **MDC** - Maximum Daily Consumption - the maximum amount of water that can be consumed in a 24-hour period. **NA** - Not Applicable. **NTU** - Nephelometric Turbidity Units - a measure of water clarity. **PPM** - Parts per million or the Milligrams per liter. **PPB** - Parts per billion or the Micrograms per liter. **PT** - Treatment Technique - a treatment technique is a required process intended to reduce the level of a contaminant in drinking water. **RAA** - Running Annual Average - an average of monitoring results for the previous 12 calendar months. **TT** - Treatment Technique - a treatment technique is a required process intended to reduce the level of a contaminant in drinking water. **Health Effects Language** - Visit the ADEQ website at [www.azdeq.gov/environment/water](http://www.azdeq.gov/environment/water) or contact the City of Douglas 2019 Water Division Supervisor, Elberto Acosta at 520-417-7536 or [Elbert@cityofdouglas.gov](mailto:Elbert@cityofdouglas.gov).

If **Arsenic** is less than or equal to the MCL, your drinking water meets EPA's standard. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continue to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

**Lead**, in drinking water, is primarily from materials and components associated with service lines and home plumbing. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. The City of Douglas is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

**Water System Detected Contaminants**

Microbiological (RTCR)	TT Violation Y or N	Number of Samples Present	Samples Absent (A)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Total Coliform Bacteria (System takes ≥ 15 monthly samples)	N	0	180	0	0	2020	Naturally Present in Environment
<b>Disinfectants</b>	<b>MCL Violation Y or N</b>	<b>Running Annual Average (RAA)</b>	<b>Range of All Samples (Low-High)</b>	<b>MCL</b>	<b>MCLG</b>	<b>Sample Month &amp; Year</b>	<b>Likely Source of Contamination</b>
Chlorine (ppm)	N	1.5	1.5 – 1.8	MRDL = 4	MRDLG = 0	2020	Water additive used to control microbes
<b>Disinfection By-Products</b>	<b>MCL Violation Y or N</b>	<b>Running Annual Average (RAA) OR Highest Level Detected</b>	<b>Range of All Samples (Low-High)</b>	<b>MCL</b>	<b>MCLG</b>	<b>Sample Month &amp; Year</b>	<b>Likely Source of Contamination</b>
Haloacetic Acids (HAA5) Stage II (ppb)	N	<0.0020	0 - <0.0020	60	N/A	2020	Byproduct of drinking water disinfection
Total Trihalomethanes (TTHM) Stage II (ppb)	N	1.3	0 – 12.3	80	N/A	2020	Byproduct of drinking water disinfection
<b>Lead &amp; Copper</b>	<b>MCL Violation Y or N</b>	<b>90<sup>th</sup> Percentile</b>	<b>Range of All Samples (Low-High)</b>	<b>AL</b>	<b>ALG</b>	<b>Sample Month &amp; Year</b>	<b>Likely Source of Contamination</b>

Copper (ppm)	N	0.071	0.021 – 0.24	AL = 1.3	ALG = 1.3	8/2019	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb)	N	0	0 – 5.0	AL = 15	0	8/2019	Corrosion of household plumbing systems; erosion of natural deposits
<b>Radionuclides</b>	<b>MCL Violation Y or N</b>	<b>Running Annual Average (RAA) OR Highest Level Detected</b>	<b>Range of All Samples (Low-High)</b>	<b>MCL</b>	<b>MCLG</b>	<b>Sample Month &amp; Year</b>	<b>Likely Source of Contamination</b>
Alpha emitters (pCi/L)	N	4.6	0 – 4.6	15	0	8/2019	Erosion of natural deposits
Gross Beta emitters (pCi/L)	N	3.5	0 – 3.5	5	0	8/2019	Decay of natural and man-made deposits
<b>Inorganic Chemicals (IOC)</b>	<b>MCL Violation Y or N</b>	<b>Running Annual Average (RAA) OR Highest Level Detected</b>	<b>Range of All Samples (Low-High)</b>	<b>MCL</b>	<b>MCLG</b>	<b>Sample Month &amp; Year</b>	<b>Likely Source of Contamination</b>
Arsenic (ppb)	N	3.1	1.2 – 6.6	10	0	6/2019	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Sodium (ppm)	N	83	62 - 130	N/A	N/A	6/2019	Erosion of natural deposits
Barium (ppm)	N	0.069	0.011 – 0.098	2	2	6/2019	Discharge of drilling wastes; discharge from metal refineries; Erosion of natural deposits
Chromium (ppb)	N	0.83	0 – 5	100	100	6/2019	Discharge from steel and pulp mills; Erosion of natural deposits
Fluoride (ppm)	N	0.46	0.38 - 0.57	4	4	6/2019	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (ppm)	N	1.4	.95-2.06	10	10	6/2020	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium (ppb)	N	1.4	0 – 2.3	50	50	6/2019	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines

### Requirements Not Met:

#### Violations

One (1) Missed Monitoring Deficiency for the Stage 2 Disinfection Byproducts for the 4<sup>th</sup> Quarter 2020 monitoring period.

One (1) Reporting Deficiency for Stage 2 Disinfection Byproducts (DBP2). Failed to submit the 4<sup>th</sup> Quarter 2020 monitoring results.

### Simple Steps to Save Water

Saving water around the home is simple and smart. The average household spends as much as \$600 per year on its water and sewer bill but could save about \$50 per year by retrofitting with water efficient fixtures and incorporating water saving practices.

**Let Water Sense show you how to save water - and your wallet.** How much money you save will depend on the cost of water where you live, but it makes sense that using less water lowers your utility bill. More importantly, using less water preserves this limited resource for generations to come.

### Inside the Home

#### Get Flush With Savings

- Consider installing a WaterSense labeled toilet, which uses 20 percent less water while offering equal or superior performance. Compared to older, inefficient models, WaterSense labeled toilets could save a family of **four** more than \$90 annually on its water utility bill, and \$2,000 over the lifetime of the toilets.

#### Accessorize Your Faucet

- Installing a WaterSense labeled aerator is one of the most cost-effective ways to save water. Also, consider replacing the entire faucet with a WaterSense labeled model. Either way, you can increase the faucet's efficiency by 30 percent without sacrificing performance.

### Outside the Home

#### Water When Needed

- Water your lawn or garden during the cool morning hours, as opposed to midday, to reduce evaporation.
- Look for sprinklers that produce droplets, not mist, or use soaker hoses or trickle irrigation for trees and shrubs.
- Set sprinklers to water lawns and gardens only. Check that you're not watering the street or sidewalk.

Helpline: (866) WTR-SENS (987-7367) Contact Us at Office of Water WaterSense, U.S. Environmental Protection Agency, Office of Wastewater Management (4204M), 1200 Pennsylvania Avenue, N.W. Washington, D.C. 20460

(WaterSense is a [U.S. Environmental Protection Agency](#) program designed to encourage [water efficiency](#) in the [U.S](#) through the use of a special [label](#) on [consumer products](#). It was launched in June, 2006.<sup>[1]</sup>)

<u>City of Douglas</u>	<u>Important Telephone Numbers:</u>	
Water & Sewer Utilities	520-417-7334	Arizona
Department of Environmental Quality (ADEQ), Utility Billing	520-417-7334	602-771-
4641		
24-Hour Emergency Services	520-417-7550	U.S.
Environmental Protection Agency (EPA)		520-740-
8261		
Public Works Department	520-417-7329	Safe Drinking
Water Hotline	1-800-426-4791	
Environmentalist	520-417-7310	

# 2020 UCMR4

Unregulated contaminants are those that don't yet have a drinking water standard set by USEPA. The purpose of monitoring for these contaminants

is to help USEPA decide whether the contaminants should have a standard.

### Water Quality Table - Unregulated Contaminants

<b>Metals</b>	<b>Detected (Y/N)</b>	<b>Average</b>	<b>Range of all Samples (Low - High)</b>	<b>MRL</b>	<b>Likely Source of Contamination</b>
Manganese (ppt)	Y	670	460 - 4200	400	Naturally-occurring element; commercially available in combination with other elements and minerals; used in steel production, fertilizer, batteries and fireworks; drinking water and wastewater treatment chemical; essential nutrient.
Germanium (ppt)	Y	60	0 - 362	300	Naturally-occurring element; commercially available in combination with other elements and minerals; a by-product of zinc ore processing; used in infrared optics, fiber-optic systems, electronics and solar applications.
<b>Disinfectants</b>	<b>Detected (Y/N)</b>	<b>Average</b>	<b>Range of all Samples (Low - High)</b>	<b>MRL</b>	<b>Likely Source of Contamination</b>
Bromide (ppm)	Y	.102	.0114 - .136	.02	By-products of drinking water disinfection.
Bromochloroacetic Acid (ppb)	Y	.099	.359 - .438	.3	By-products of drinking water disinfection.
Dibromoacetic Acid (ppb)	Y	.498	.305 - 1.19	.3	By-products of drinking water disinfection.